



Electrical Room 1201

Scale: 1/4" = 1'

Notes:

1

Preferred location of pull box for second floor panel feeders (elevator pit foundation may interfere). If mounted here, mount as low as possible on the wall.

2

Alternate location of pull box for second floor panel feeders.

3

8"D x 14"W x 14" T pull box. See E6.02 to verify.

ES7.02

v. 07-09-08